

Subject:	INDOOR AIR QUALITY
Section:	PPG# 4100.10
Chapter:	Operations
Effective Date:	7/1/98

1.0 POLICY

- 1.1** Air quality shall be consistent with WAC 296-62-075 through 07515, Air contaminants and WAC 296-62-1200 through 1209, Environmental tobacco smoke in office environments.
- 1.2** All fixed internal combustion equipment such as, but not limited to emergency generators, shall be effectively exhausted to the exterior of the fire station.
- 1.3** All facilities dedicated to the maintenance and repair of internal combustion equipment shall have means for effective ventilation to the exterior of the building.

2.0 REFERENCES

WAC 296-305-06511

[Statutory Authority: RCW 49.17.010, .050, .060. 96-11-067 (Order 94-27), §296-305-06511, filed 05/10/96, effective 01/01/97.]